



DRAFT

**Interconnection Feasibility Study Report
Request # GI-2012-3**

60 MW Wind Generation Facility Expansion at Spring Canyon

PSCo Transmission Planning
May 24, 2013

Executive Summary

On May 22, 2012, Public Service Company of Colorado (PSCo) Transmission received a generation request to determine the feasibility of interconnecting a 60 MW wind generation expansion to the existing 60 MW Spring Canyon Energy wind generation facility located at the jointly owned Spring Canyon Substation in Logan County Colorado. Generation from the expansion will be supplied to the PSCo Balancing Authority (BA). The Customer requested a primary Point of Interconnection (POI) on the 230 kV bus at the existing Spring Canyon Substation. No alternative POI was requested. The Customer proposed a commercial operation date of December 1, 2013. Based on projected equipment lead-times and other transmission project in service dates, the commercial operation date requested by the Customer is not feasible.

This request was studied as an Energy Resource (ER)¹ only. The study included steady-state power flow and short-circuit analysis only, and did not include a transient dynamic stability analysis. The request was studied as a stand-alone project only, with no evaluations made of other potential new generation requests that may exist in the Large Generator Interconnection Request (LGIR) queue, other than the generation projects that are already approved and planned to be in service by the winter of 2013. The main purpose of this Feasibility Study was to evaluate the potential impact on the PSCo transmission infrastructure as well as that of neighboring utilities, when injecting the new 60 MW of generation into the Spring Canyon 230 kV bus, and delivering the additional generation to the PSCo BA. Affects on other entities' nearby transmission systems will need to be analyzed by the affected parties.

¹ **Energy Resource Interconnection Service (ER Interconnection Service)** shall mean an Interconnection Service that allows the Interconnection Customer to connect its Generating Facility to the Transmission Provider's Transmission System to be eligible to deliver the Generating Facility's electric output using the existing firm or non-firm capacity of the Transmission Provider's Transmission System on an as available basis. Energy Resource Interconnection Service in and of itself does not convey transmission service.



A 2013 Heavy Summer (HS) Western Electricity Coordinating Council (WECC) case was used to conduct the study. This benchmark case scenario was used to analyze the impacts when adding GI-2012-3 to the existing transmission system. The generation dispatch for this benchmark case was adjusted to simulate high north-to-south flow levels across the TOT3 transfer path. Wind generation at the existing Spring Canyon was modeled at 21% in the benchmark case and increased to 100% with the addition of GI-2012-3. Single contingencies were applied.

With the addition of GI-2012-3, the parallel 34.5/230 kV generator step-up (GSU) transformers at Spring Canyon were overloaded by 162% of their thermal rating when one transformer was taken out of service². Additionally, the Sidney 230/115 kV transformer was overloaded by 115.5% when the North Yuma – Spring Canyon 230 kV line was taken out of service. Currently there is an operation procedure in place to curtail the wind generation to 0 MW at Spring Canyon in the event of this outage; however, the Customer will need to contact TSGT to discuss mitigation of this transformer overload when interconnecting GI-2012-3. Finally, the Alvin – Wauneta 115 kV line is overloaded by 101.6% when the North Yuma – Wray 230 kV line is taken out of service. Low voltage violations (below 0.90 per unit) were observed at Burlington 115 kV, 230 kV and the two 13.8 kV generator busses when the Lands Creek to Burlington 230 kV line was taken out of service due to the addition of GI-2012-3.

Energy Resource (ER)

ER = 0 MW

Interconnection to the PSCo network is feasible however, firm capacity is not available due to existing firm transmission commitments, and is not possible without the construction of network reinforcements. Currently PSCo has 110 MW of capacity rights on the Story – North Yuma 230 kV transmission line and uses 56 MW of this capacity to maintain their contractual transmission reliability margin (TRM). Capacity on the Story – North Yuma line is exceeded by 6 MW when accounting for the TRM and the 60 MW of the existing Spring Canyon generation facility and prior to the 60 MW expansion. Non-firm transmission capability may be available depending on marketing activities, dispatch patterns, generation levels, demand levels, import path levels (TOT 3, etc.) and the operational status of transmission facilities.

The cost for the transmission interconnection (in 2013 dollars):

The total estimated cost of the recommended system upgrades to interconnect the project is approximately **\$ 21,511** and includes:

- \$ 0 for PSCo-Owned, Customer-Funded Interconnection Facilities

² The rating of the Spring Canyon GSU transformers in the case was 74.7 MVA which is greater than the 66.6 MVA rating supplied in the customer one-line diagram. The larger rating in the case was assumed.



- \$ 21,511 for PSCo-Owned, PSCo-Funded Network Upgrades for Interconnection
- \$ 0 for PSCo Network Upgrades for Delivery

A partial one-line of the Spring Canyon Substation detailing the Interconnection and Delivery is shown in Figure 1.




Figure 1: Proposed Spring Canyon One-Line Diagram (Upgrades Marked in Red)



Introduction

Public Service Company of Colorado (PSCo) Transmission Planning received a generation request on May 22, 2012, to determine the feasibility of interconnecting a 60 MW wind generation expansion to the existing 60 MW Spring Canyon Energy wind generation facility. The Customer's project facility would consist of 37 GE 1.6 MW wind turbines and would be located immediately adjacent to the existing Spring Canyon Energy Facility, near Peetz Colorado in Logan County. Generation from the expansion will be supplied to the PSCo Balancing Authority (BA) and delivered to PSCo native load customers.

The Customer requested a primary Point of Interconnection (POI) on the 230 kV bus at the existing Spring Canyon Substation. No alternative POI was requested.

The Customer proposed a commercial operation date of December 1, 2013. Based on projected equipment lead-times and other transmission project in service dates, the commercial operation date requested by the Customer is not feasible.

The Customer has requested that this project be evaluated as an Energy Resource (ER) only, with the generation delivered to PSCo native load customers.

Study Scope and Analysis

PSCo conducted a Feasibility Study Analysis for the interconnection of a 60 MW wind generation expansion to the existing 60 MW Spring Canyon Energy wind generation facility. The analysis consisted of power flow and short circuit analyses. The power flow analysis provided a preliminary identification of any thermal or voltage limit violations resulting for the interconnection. The short circuit analysis identified any circuit breaker short circuit capability limits exceeded as a result of the Interconnection.

PSCo adheres to NERC / WECC Reliability Criteria, as well as internal Company criteria for planning studies. During system intact conditions, transmission system bus voltages are to be maintained between 0.95 and 1.05 per-unit of system nominal / normal conditions, and steady state power flows within 1.0 per-unit of all elements thermal (continuous current or MVA) ratings. Operationally, PSCo tries to maintain a transmission system voltage profile ranging from 1.03 per-unit or higher at generation buses, to 1.0 per-unit or higher at transmission load buses. Following a single contingency element outage, transmission system steady state bus voltages must remain within 0.90 per-unit to 1.05 per-unit, and power flows within 1.0 per-unit of the elements continuous thermal ratings.

For this project, potential affected parties include Western Area Power Administration (WAPA) and Tri-State Generation & Transmission (TSGT). PSCo has coordinated and cooperated on its study assessment through e-mail and phone correspondence and has also forwarded a copy of this feasibility study report to the affected parties.



Power Flow Study Models

A 2013 Heavy Summer (HS) Western Electricity Coordinating Council (WECC) case was modified to reflect topological, loading and generation changes as discussed with the affected parties and the Customer. This benchmark case scenario was used to analyze the impacts when adding GI-2012-3 to the existing transmission system. Automated contingency power flow studies were completed on all case models, switching out single elements (lines and transformers) one at a time in the study area. Results from the contingency analyses were compared to identify thermal or voltage limit violations resulting from the addition of GI-2012-3.

Generation dispatch in area 70 (PSCo) for the benchmark case was adjusted to simulate high north-to-south flow levels across the TOT3 transfer path. The TOT3 interface flow was set to 1346.9 MW and the TOT7 interface flow was set to 400.0 MW. Manchief units 1 and 2, Ft. St. Vrain units 5 and 6, and UNC units 1, 2 and 3 were each set off-line, while the Rawhide units A, B and D were turned on.

PSCo control area (Area 70) wind generation facilities near Pawnee, Missile Site, and the Peetz Logan and Cedar Creek facilities were dispatched at approximately 21% of their respective ratings. Wind generation at the existing Spring Canyon facility was modeled at 21% and increased to 100% with the addition of GI-2012-3.

A complete list of the generation facilities for each of the models in area 70 (PSCo) and area 73 (WAPA) is presented in Table A1 in the Appendix.

The proposed generation expansion facility, as modeled, consists of one lumped generation unit representing the 37 individual GE 1.6 MW wind turbines. The generator has a terminal voltage of 34.5 kV and is connected to the 230 kV system through one 34.5/230 kV transformer. The 34.5/230 kV transformer is in parallel with another existing transformer for the current generation facility. For modeling purposes, the generator was set to control the bus voltage on the facility's 34.5 kV bus to 1.030 per-unit.

A single-line diagram showing the transmission system model with high TOT3 flows is presented as Figure B1 in the Appendix. Figure B2 in the Appendix indicates the flows with the addition of the GI-2012-3 project.

Stand Alone Power Flow Results

ER = 0 MW

Interconnection to the PSCo network is feasible however, firm capacity is not available due to existing firm transmission commitments, and is not possible without the construction of network reinforcements. Currently PSCo has 110 MW of capacity rights



on the Story – North Yuma 230 kV transmission line and uses 56 MW of this capacity to maintain their contractual transmission reliability margin (TRM). Capacity on the Story – North Yuma line is exceeded by 6 MW when accounting for the TRM and the 60 MW of the existing Spring Canyon generation facility and prior to the 60 MW expansion. Non-firm transmission capability may be available depending on marketing activities, dispatch patterns, generation levels, demand levels, import path levels (TOT 3, etc.) and the operational status of transmission facilities.

With the addition of GI-2012-3, the parallel 34.5/230 kV generator step-up (GSU) transformers at Spring Canyon were overloaded by 162% of their thermal rating when one transformer was taken out of service. It is recommended that the customer upgrade these transformers to handle the maximum output of the generation facility in the event one transformer needs to be taken out of service.

PSCo's Weld – Greeley 115 kV line is also overloaded by 111.5%; however this is not related to the addition of GI-2012-3. This overload is a result of the generation changes made to the WECC 2013 HS case with the retirement of the UNC generation facilities. PSCo is currently upgrading its facilities at Weld in order to increase the rating of the line from 181 MVA to 219 MVA, thereby eliminating the overload.

Additionally, the Sidney 230/115 kV transformer was overloaded by 115.5% when the North Yuma – Spring Canyon 230 kV line was taken out of service. Currently there is an operation procedure in place to curtail the wind generation to 0 MW at Spring Canyon in the event of this outage. WAPA has also indicated there are currently limitations related to the Spring Canyon generation facility for N-1 outages of the Spring Canyon – North Yuma 230 kV line based on contract path ratings. When adding GI-2012-3 for a total of 120 MW of wind generation (60 MW existing plus 60 MW expansion), the above mentioned operating procedure would not be allowed as a means to mitigate overloads above the Sidney transformer's 203 MVA (continuous and emergency) rating. Therefore, some other mitigation will be required for the full 120 MW Spring Canyon facility. The Customer will need to contact TSGT to discuss mitigation of this transformer overload when interconnecting GI-2012-3.

Finally, with the addition of GI-2012-3, the Alvin – Wauneta 115 kV line is overloaded by 101.6% when the North Yuma – Wray 230 kV line is taken out of service. WAPA has indicated that the limiting elements on the Alvin line termination at Wauneta are presently rated at 200 A (40 MVA, not the 43 MVA shown in the case / study), and are based on SCADA transducers or panel meters which are fed from the WAPA breakers 262 & 362 bushing CTs. The Customer will need to contact WAPA to discuss mitigation of this elemental overload when interconnecting GI-2012-3.

Low voltage violations (below 0.90 per unit) were observed at Burlington 115 kV, 230 kV and the two 13.8 kV generator busses when the Lands Creek to Burlington 230 kV line was taken out of service due to the addition of GI-2012-3. Results from the contingency analysis can be seen below in Table 1.



| Contingency | Monitored Element | WECC 2013HS Case | | | Benchmark Stressed Case | | Stressed with GI-2012-3 | |
|---|--|-------------------|------------|---------------------|-------------------------|---------------------|-------------------------|---------------------|
| | | Line Rating (MVA) | Flow (MVA) | Percent Loading (%) | Flow (MVA) | Percent Loading (%) | Flow (MVA) | Percent Loading (%) |
| BUS 70005 [BRUSH_SS 115.00] TO BUS 70397 [B.CRK_PS 115.00] CKT 2 | 70005 BRUSH_SS 115.00 70397 B.CRK_PS 115.00 1 | 181 | 192 | 105.3 | 192 | 105.3 | 193 | 105.6 |
| BUS 70005 [BRUSH_SS 115.00] TO BUS 70397 [B.CRK_PS 115.00] CKT 1 | 70005 BRUSH_SS 115.00 70397 B.CRK_PS 115.00 2 | 181 | 193 | 105.5 | 193 | 105.5 | 193 | 105.8 |
| BUS 70470 [WELD_PS 115.00] TO BUS 70475 [ARROWHLK 115.00] CKT 1 | 70209 GREELEY 115.00 70470 WELD_PS 115.00 1 | 181 | | | 203 | 111.5 | 203 | 111.3 |
| BUS 70310 [PAWNEE 22.000] TO BUS 70311 [PAWNEE 230.00] CKT U2 | 70310 PAWNEE 22.000 70311 PAWNEE 230.00 U1 | 364 | 487 | 133.8 | 486 | 133.5 | 487 | 133.8 |
| BUS 70310 [PAWNEE 22.000] TO BUS 70311 [PAWNEE 230.00] CKT U1 | 70310 PAWNEE 22.000 70311 PAWNEE 230.00 U2 | 364 | 487 | 133.8 | 486 | 133.4 | 487 | 133.8 |
| BUS 70721 [SPRNGCAN 34.500] TO BUS 73579 [SPRNGCAN 230.00] CKT 2 | 70721 SPRNGCAN 34.500 73579 SPRNGCAN 230.00 1 | 74.7 | | | | | 121 | 162.2 |
| BUS 73143 [N.YUMA 230.00] TO BUS 73224 [WRAY 230.00] CKT 1 | 73005 ALVIN 115.00 73210 WAUNETA 115.00 1 | 43 | 43 | 100.1 | | | 44 | 101.6 |
| BUS 73143 [N.YUMA 230.00] TO BUS 73579 [SPRNGCAN 230.00] CKT 1 | 73179 SIDNEY 115.00 73180 SIDNEY 230.00 1 | 203 | | | | | 234 | 115.5 |
| BUS 73189 [STEGALL 115.00] TO BUS 73190 [STEGALL 230.00] CKT 2 | 73189 STEGALL 115.00 73190 STEGALL 230.00 1 | 100 | 107 | 107.3 | 107 | 107.1 | 107 | 106.7 |
| BUS 70721 [SPRNGCAN 34.500] TO BUS 73579 [SPRNGCAN 230.00] CKT 1 | 70721 SPRNGCAN 34.500 73579 SPRNGCAN 230.00 2 | 74.7 | | | | | 121 | 162.2 |
| Contingency | Monitored Element | | | Voltage (pu) | | Voltage (pu) | | Voltage (pu) |
| BUS 72710 [LANDS.CRK1 230.00] TO BUS 73036 [BURLNGTN 230.00] CKT 1 | 73035 BURLNGTN 115.00 | | | | | | | 0.89768 |
| BUS 72710 [LANDS.CRK1 230.00] TO BUS 73036 [BURLNGTN 230.00] CKT 1 | 73036 BURLNGTN 230.00 | | | | | | | 0.89768 |
| BUS 72710 [LANDS.CRK1 230.00] TO BUS 73036 [BURLNGTN 230.00] CKT 1 | 73302 BRLNGTN1 13.800 | | | | | | | 0.89768 |
| BUS 72710 [LANDS.CRK1 230.00] TO BUS 73036 [BURLNGTN 230.00] CKT 1 | 73303 BRLNGTN2 13.800 | | | | | | | 0.89768 |

Table 1: Contingency Analysis for GI-2012-3

Short Circuit Study Results

A short circuit breaker duty analysis was conducted to determine if the available fault current (single-line-to ground or three-phase) exceeds the interrupt ratings of any circuit breakers at the Spring Canyon Substation. The fault study compared the available fault current at the Spring Canyon Substation before and after the addition of the proposed new generation injected at the POI. Table 2 below summarizes the results of the short circuit analysis.

Table 2: Short-Circuit Study Results With the Proposed 60 MW of Generation

| System Condition | Three-phase (amps) | Thevenin System Equivalent Impedance (R,X) (ohms) | Single-line-to-ground (amps) | Thevenin System Equivalent Impedance (R,X) (ohms) |
|------------------|---|---|---|---|
| System Intact | I ₁ =4,139.84 I ₂ =I ₀ =0 I _A =I _B =I _C =4,139.84 | Z ₁ (pos)= 4.28023, 31.7894 Z ₂ (neg)= 4.63927, 34.7776 Z ₀ (zero)= 6.51284, 34.7392 | I ₁ =I ₂ =1,295.84 I ₀ =3887.51 I _A =3887.51 I _B =I _C =0 | Z ₁ (pos)= 4.28023, 31.7894 Z ₂ (neg)= 4.63927, 34.7776 Z ₀ (zero)= 6.51284, 34.7392 |

Fault currents at the Spring Canyon 230 kV bus after the addition of GI-2012-3 are 3,888 amps for single-line to ground faults, and 4,140 amps for a three-phase fault.



Results of the short circuit analysis show that the fault current levels at the Spring Canyon 230 kV bus are within the interrupting ratings of the breakers; therefore, the addition of the generation interconnection project and associated infrastructure will not cause fault currents to exceed the circuit breaker ratings.

Costs Estimates and Assumptions

The estimated total cost for the required upgrades for is **\$ 21,511**. The estimated costs shown are (+/-30%) estimates in 2013 dollars (no escalation applied) and are based upon typical construction costs for previously performed similar construction. These estimated costs include all applicable labor and overheads associated with the siting, engineering, design, procurement and construction of these new PSCo facilities. This estimate does not include the cost for any other Customer owned equipment and associated design and engineering.

The following tables list the improvements required to accommodate the interconnection and the delivery of the Project. The cost responsibilities associated with these facilities shall be handled as per current FERC guidelines. System improvements are subject to change upon more detailed analysis.

| Estimate Summary | | | | | |
|--------------------------------------|--------------|------------------|-----------------|--------------|-----------------|
| WBS Costs | Labor | Equipment | Material | Other | Total |
| CBS1 - Permitting/Project Management | \$0 | \$0 | \$0 | \$0 | \$0 |
| CBS2 - Engineering/Design | \$8,256 | \$0 | \$0 | \$0 | \$8,256 |
| CBS3 - Civil Construction | \$0 | \$0 | \$0 | \$0 | \$0 |
| CBS4 - Electrical Construction | \$4,901 | \$1,240 | \$2,937 | \$209 | \$9,287 |
| CBS5 - Construction Remove | \$0 | \$0 | \$0 | \$0 | \$0 |
| CBS6 - Commissioning | \$0 | \$0 | \$0 | \$0 | \$0 |
| CBS7 - CIAC and Other | \$0 | \$0 | \$0 | \$0 | \$0 |
| Direct Cost Subtotal | \$13,157 | \$1,240 | \$2,937 | \$209 | \$17,543 |
| Indirect Costs | | | | | |
| Powerplant Overheads (E&S + A&G) | \$553 | \$10 | \$123 | \$51 | \$737 |
| Material overheads | \$460 | \$8 | \$103 | \$42 | \$614 |
| AFUDC | \$316 | \$6 | \$70 | \$29 | \$421 |
| Contingency | \$1,316 | \$24 | \$294 | \$121 | \$1,754 |
| Escalation | \$332 | \$6 | \$74 | \$30 | \$442 |
| Indirect Cost Subtotal | \$2,976 | \$54 | \$664 | \$273 | \$3,969 |
| Project Total | | | | | \$21,511 |

Assumptions for Alternatives

- Scoping level cost estimates for Interconnection Facilities and Network/Infrastructure Upgrades for Delivery (+/- 30% accuracy) were developed by Xcel Energy/PSCo Engineering staff.



- Estimates are based on 2013 dollars (appropriate contingency and escalation applied).
- AFUDC has been excluded.
- Engineering will be performed in house.
- Lead times for materials were considered for the schedule.
- The Generation Facility is not in PSCo's retail service territory.
- PSCo (or it's Contractor) crews will perform all construction, wiring, testing and commissioning for PSCo owned and maintained facilities.
- Construction labor is estimated for straight time only – no overtime included.
- The estimated time to design, procure and construct the interconnection facilities is approximately 6 months after authorization to proceed has been obtained.
- Authorization to proceed is considered to be the execution of the LGIA.
- This project is completely independent of other queued projects and their respective ISD's.
- Line and substation bus outages will need to be authorized during the construction period to meet requested backfeed dates.

Project Schedule

The estimated time to design, procure and construct the interconnection facilities is approximately 6 months after authorization to proceed has been obtained. Authorization to proceed is considered to be the execution of the LGIA.



Appendix

A. Generation Dispatch

Table A1: Generation Dispatch

| Bus Number | Bus Name | | Case | Benchmark | GI-2012-3 |
|------------|----------|--------|-----------|-----------|-----------|
| | | | Pgen (MW) | Pgen (MW) | Pgen (MW) |
| 70034 | ARAP3 | 13.800 | 40 | 40 | 40 |
| 70035 | ARAP4 | 13.800 | 98 | 98 | 98 |
| 70069 | CABCRKA | 13.800 | 80 | 80 | 80 |
| 70070 | CABCRKB | 13.800 | 80 | 80 | 80 |
| 70083 | CANON_55 | 13.800 | 14 | 14 | 14 |
| 70084 | CANON_59 | 13.800 | 20 | 20 | 20 |
| 70104 | CHEROK2 | 15.500 | 0 | 0 | 0 |
| 70105 | CHEROK3 | 20.000 | 143.2704 | 97.2294 | 97.7615 |
| 70106 | CHEROK4 | 22.000 | 360 | 383 | 383 |
| 70119 | COMAN_1 | 24.000 | 355 | 355 | 355 |
| 70120 | COMAN_2 | 24.000 | 360 | 360 | 360 |
| 70310 | PAWNEE | 22.000 | 505 | 505 | 505 |
| 70314 | MANCHEF1 | 16.000 | 130 | 0 | 0 |
| 70315 | MANCHEF2 | 16.000 | 130 | 0 | 0 |
| 70344 | R.F.DSLS | 4.1600 | 8 | 8 | 8 |
| 70350 | RAWHIDE | 24.000 | 300 | 300 | 300 |
| 70351 | RAWHIDEA | 13.800 | 0 | 60 | 60 |
| 70385 | SHOSHA&B | 4.0000 | 7 | 7 | 7 |
| 70385 | SHOSHA&B | 4.0000 | 8 | 8 | 8 |
| 70406 | ST.VR_2 | 18.000 | 130 | 130 | 130 |
| 70407 | ST.VR_3 | 18.000 | 130 | 130 | 130 |
| 70408 | ST.VR_4 | 18.000 | 130 | 130 | 130 |
| 70409 | ST.VRAIN | 22.000 | 300 | 300 | 300 |
| 70446 | VALMONT | 20.000 | 160 | 160 | 160 |
| 70448 | VALMONT6 | 13.800 | 50 | 50 | 50 |
| 70487 | QF_TC-T4 | 13.800 | 33.7 | 33.7 | 33.7 |
| 70487 | QF_TC-T4 | 13.800 | 33.7 | 33.7 | 33.7 |
| 70490 | QF_TC-T3 | 13.800 | 33.7 | 33.7 | 33.7 |
| 70490 | QF_TC-T3 | 13.800 | 51.7 | 51.7 | 51.7 |
| 70498 | QF_BCP2T | 13.800 | 19.4 | 19.4 | 19.4 |
| 70498 | QF_BCP2T | 13.800 | 19.3 | 19.3 | 19.3 |
| 70499 | QF_B4-4T | 13.800 | 20 | 20 | 20 |
| 70499 | QF_B4-4T | 13.800 | 20 | 20 | 20 |
| 70500 | QF_CPP1T | 13.800 | 20 | 20 | 20 |
| 70500 | QF_CPP1T | 13.800 | 20 | 20 | 20 |
| 70501 | QF_CPP3T | 13.800 | 27 | 27 | 27 |
| 70502 | QF_UNC | 13.800 | 25 | 0 | 0 |



| | | | | | |
|-------|----------|--------|-----|-----|-----|
| 70502 | QF_UNC | 13.800 | 25 | 0 | 0 |
| 70502 | QF_UNC | 13.800 | 15 | 0 | 0 |
| 70503 | PONNEQUI | 26.100 | 6.3 | 6.3 | 6.3 |
| 70556 | QF_B4D4T | 12.500 | 50 | 50 | 50 |
| 70560 | LAMAR_DC | 230.00 | 0 | 200 | 101 |
| 70561 | RAWHIDEF | 18.000 | 125 | 135 | 135 |
| 70562 | SPRUCE1 | 18.000 | 130 | 130 | 130 |
| 70563 | SPRUCE2 | 18.000 | 130 | 130 | 130 |
| 70565 | BRTNNUG1 | 13.800 | 35 | 35 | 35 |
| 70567 | RAWHIDED | 13.800 | 0 | 60 | 60 |
| 70568 | RAWHIDEB | 13.800 | 0 | 60 | 60 |
| 70569 | RAWHIDEC | 13.800 | 54 | 60 | 60 |
| 70580 | PLNENDG1 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70580 | PLNENDG1 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70580 | PLNENDG1 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70580 | PLNENDG1 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70580 | PLNENDG1 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70580 | PLNENDG1 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70580 | PLNENDG1 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70580 | PLNENDG1 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70580 | PLNENDG1 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70580 | PLNENDG1 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70580 | PLNENDG1 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70580 | PLNENDG1 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70580 | PLNENDG1 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70580 | PLNENDG1 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70585 | PLNENDG3 | 13.800 | 7.2 | 7.2 | 7.2 |
| 70585 | PLNENDG3 | 13.800 | 7.2 | 7.2 | 7.2 |
| 70585 | PLNENDG3 | 13.800 | 7.2 | 7.2 | 7.2 |
| 70585 | PLNENDG3 | 13.800 | 7.2 | 7.2 | 7.2 |
| 70585 | PLNENDG3 | 13.800 | 7.2 | 7.2 | 7.2 |
| 70585 | PLNENDG3 | 13.800 | 7.2 | 7.2 | 7.2 |
| 70585 | PLNENDG3 | 13.800 | 7.2 | 7.2 | 7.2 |
| 70585 | PLNENDG3 | 13.800 | 7.2 | 7.2 | 7.2 |
| 70585 | PLNENDG3 | 13.800 | 7.2 | 7.2 | 7.2 |
| 70585 | PLNENDG3 | 13.800 | 7.2 | 7.2 | 7.2 |
| 70586 | PLNENDG4 | 13.800 | 7.2 | 7.2 | 7.2 |
| 70586 | PLNENDG4 | 13.800 | 7.2 | 7.2 | 7.2 |
| 70586 | PLNENDG4 | 13.800 | 7.2 | 7.2 | 7.2 |
| 70586 | PLNENDG4 | 13.800 | 7.2 | 7.2 | 7.2 |
| 70586 | PLNENDG4 | 13.800 | 7.2 | 7.2 | 7.2 |
| 70586 | PLNENDG4 | 13.800 | 7.2 | 7.2 | 7.2 |
| 70586 | PLNENDG4 | 13.800 | 7.2 | 7.2 | 7.2 |
| 70586 | PLNENDG4 | 13.800 | 7.2 | 7.2 | 7.2 |
| 70586 | PLNENDG4 | 13.800 | 7.2 | 7.2 | 7.2 |
| 70586 | PLNENDG4 | 13.800 | 7.2 | 7.2 | 7.2 |
| 70587 | PLNENDG2 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70587 | PLNENDG2 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70587 | PLNENDG2 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70587 | PLNENDG2 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70587 | PLNENDG2 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70587 | PLNENDG2 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70587 | PLNENDG2 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70587 | PLNENDG2 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70587 | PLNENDG2 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70587 | PLNENDG2 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70587 | PLNENDG2 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70587 | PLNENDG2 | 13.800 | 4.8 | 4.8 | 4.8 |
| 70588 | RMEC1 | 15.000 | 95 | 142 | 142 |



| | | | | | |
|-------|-----------------------|--------|----------|----------|----------|
| 70589 | RMEC2 | 15.000 | 90 | 141 | 141 |
| 70591 | RMEC3 | 23.000 | 255 | 322 | 322 |
| 70593 | SPNDLE1 | 18.000 | 110 | 129 | 129 |
| 70594 | SPNDLE2 | 18.000 | 110 | 129 | 129 |
| 70622 | MIS_SITE | 34.500 | 52.5 | 52.5 | 52.5 |
| 70625 | MISSILEW2 | 34.500 | 42 | 42 | 42 |
| 70626 | MISSILEW3 | 34.500 | 42 | 42 | 42 |
| 70701 | CO_GRN_E | 34.500 | 17 | 17 | 17 |
| 70702 | CO_GRN_W | 34.500 | 17 | 17 | 17 |
| 70703 | TWNBUTTE | 34.500 | 15.8 | 15.8 | 15.8 |
| 70710 | PTZLOGN1 | 34.500 | 42.2 | 42.2 | 42.2 |
| 70712 | PTZLOGN2 | 34.500 | 25.2 | 25.2 | 25.2 |
| 70713 | PTZLOGN3 | 34.500 | 16.7 | 16.7 | 16.7 |
| 70714 | PTZLOGN4 | 34.500 | 36.8 | 36.8 | 36.8 |
| 70721 | SPRNGCAN | 34.500 | 12.6 | 12.6 | 60 |
| 70721 | SPRNGCAN | 34.500 | 0 | 0 | 60 |
| 70723 | RDGCREST | 34.500 | 6.3 | 6.3 | 6.3 |
| 70777 | COMAN_3 | 27.000 | 805 | 805 | 795 |
| 70822 | CEDARCK1 | 34.500 | 31.5 | 31.5 | 31.5 |
| 70823 | CEDARCK2 | 34.500 | 31.5 | 31.5 | 31.5 |
| 70824 | CEDAR3 | 34.500 | 52.5 | 52.5 | 52.5 |
| 70931 | GR_SANDH_PV 34.500 | | 9.98 | 9.98 | 9.98 |
| 70932 | SOLAR_GE | 34.500 | 19.5 | 19.5 | 19.5 |
| 70933 | COGENTIX_PV 34.500 | | 19.5 | 19.5 | 19.5 |
| 70950 | ST.VR_5 | 18.000 | 150 | 0 | 0 |
| 70951 | ST.VR_6 | 18.000 | 100 | 0 | 0 |
| 71001 | BAC_MSA | 13.800 | 100 | 100 | 100 |
| 71002 | BAC_MSA | 13.800 | 100 | 100 | 100 |
| 71003 | BAC_MSA | 13.800 | 40 | 40 | 40 |
| 71003 | BAC_MSA | 13.800 | 40 | 40 | 40 |
| 71003 | BAC_MSA | 13.800 | 20 | 20 | 20 |
| 71004 | BAC_MSA | 13.800 | 40 | 40 | 40 |
| 71004 | BAC_MSA | 13.800 | 40 | 40 | 40 |
| 71004 | BAC_MSA | 13.800 | 20 | 20 | 20 |
| 71009 | BUSCHRWTG1 0.7000 | | 28.8 | 28.8 | 28.8 |
| 73054 | ELBERT-1 | 11.500 | 99 | 99 | 99 |
| 73129 | MBPP-1 | 24.000 | 605.0183 | 610.0098 | 613.7371 |
| 73130 | MBPP-2 | 24.000 | 605 | 605 | 605 |
| 73181 | SIDNEYDC | 230.00 | 196 | 196 | 196 |
| 73226 | YELLOW1-2 | 13.800 | 62 | 62 | 62 |
| 73226 | YELLOW1-2 | 13.800 | 62 | 62 | 62 |
| 73227 | YELLOW3-4 | 13.800 | 62 | 62 | 62 |
| 73227 | YELLOW3-4 | 13.800 | 62 | 62 | 62 |
| 73288 | NSS1 | 13.800 | 18.6 | 18.6 | 18.6 |



| | | | | | |
|-------|------------|--------|-------|-------|-------|
| 73289 | RCCT1 | 13.800 | 17 | 17 | 17 |
| 73291 | RCCT2 | 13.800 | 17 | 17 | 17 |
| 73292 | RCCT3 | 13.800 | 17 | 17 | 17 |
| 73293 | RCCT4 | 13.800 | 1.4 | 1.4 | 1.4 |
| 73299 | BIGTHOMP | 4.2000 | 4 | 4 | 4 |
| 73306 | ESTES1 | 6.9000 | 17 | 17 | 17 |
| 73307 | ESTES2 | 6.9000 | 17 | 17 | 17 |
| 73308 | ESTES3 | 6.9000 | 17 | 17 | 17 |
| 73316 | GREENMT1 | 6.9000 | 13 | 13 | 13 |
| 73317 | GREENMT2 | 6.9000 | 13 | 13 | 13 |
| 73319 | MARYLKPP | 6.9000 | 8 | 8 | 8 |
| 73324 | POEHILL | 13.800 | 36 | 36 | 36 |
| 73328 | WILLMFRK | 2.4000 | 2 | 2 | 2 |
| 73332 | ALCOVA1 | 6.9000 | 21 | 21 | 21 |
| 73333 | BOYSEN1 | 4.2000 | 7 | 7 | 7 |
| 73333 | BOYSEN1 | 4.2000 | 7 | 7 | 7 |
| 73334 | BBILL1-2 | 6.9000 | 5 | 5 | 5 |
| 73334 | BBILL1-2 | 6.9000 | 5 | 5 | 5 |
| 73339 | HEART MT | 2.4000 | 5 | 5 | 5 |
| 73341 | NSS2 | 13.800 | 93.7 | 93.7 | 93.7 |
| 73347 | SHOSHONE | 6.9000 | 2 | 2 | 2 |
| 73349 | FREMONT1 | 11.500 | 29 | 29 | 29 |
| 73350 | FREMONT2 | 11.500 | 29 | 29 | 29 |
| 73351 | GLEND01 | 6.9000 | 15 | 15 | 15 |
| 73352 | GLEND02 | 6.9000 | 15 | 15 | 15 |
| 73353 | GUERNSY1 | 2.4000 | 2.5 | 2.5 | 2.5 |
| 73356 | KORTES1 | 6.9000 | 12 | 12 | 12 |
| 73357 | KORTES2 | 6.9000 | 12 | 12 | 12 |
| 73358 | KORTES3 | 6.9000 | 12 | 12 | 12 |
| 73363 | SEMINOE1-2 | 6.9000 | 12.5 | 12.5 | 12.5 |
| 73363 | SEMINOE1-2 | 6.9000 | 12.5 | 12.5 | 12.5 |
| 73418 | RD_NIXON | 20.000 | 224.8 | 224.8 | 224.8 |
| 73424 | TESLA1 | 13.800 | 28 | 28 | 28 |
| 73427 | DRAKE 5 | 13.800 | 49 | 49 | 49 |
| 73428 | DRAKE 6 | 13.800 | 82.3 | 82.3 | 82.3 |
| 73429 | DRAKE 7 | 13.800 | 139.1 | 139.1 | 139.1 |
| 73438 | ALCOVA2 | 6.9000 | 20 | 20 | 20 |
| 73439 | BBILL3-4 | 6.9000 | 5 | 5 | 5 |
| 73441 | SEMINOE3 | 6.9000 | 13 | 13 | 13 |
| 73444 | GUERNSY2 | 2.4000 | 2.5 | 2.5 | 2.5 |
| 73448 | FLATIRN1 | 13.800 | 42 | 42 | 42 |
| 73449 | FLATIRN2 | 13.800 | 43 | 43 | 43 |
| 73449 | FLATIRN2 | 13.800 | 8 | 8 | 8 |
| 73461 | ELBERT-2 | 11.500 | 99 | 99 | 99 |
| 73462 | SPIRTMTN | 6.9000 | 4 | 4 | 4 |
| 73507 | FTRNG1CC | 18.000 | 100 | 100 | 100 |
| 73508 | FTRNG2CC | 18.000 | 100 | 100 | 100 |



| | | | | | |
|-------|------------|--------|-------|-------|-------|
| 73509 | FTRNG3CC | 21.000 | 162 | 162 | 162 |
| 73532 | LINCOLN1 | 13.800 | 50 | 50 | 50 |
| 73533 | LINCOLN2 | 13.800 | 50 | 50 | 50 |
| 73631 | COHIWND_G1 | 0.6900 | 67 | 67 | 67 |
| 74014 | NSS_CT1 | 13.800 | 40 | 40 | 40 |
| 74015 | NSS_CT2 | 13.800 | 40 | 40 | 40 |
| 74016 | WYGEN | 13.800 | 93.7 | 93.7 | 93.7 |
| 74017 | WYGEN2 | 13.800 | 95 | 95 | 95 |
| 74018 | WYGEN3 | 13.800 | 110 | 110 | 110 |
| 74029 | LNG_CT1 | 13.800 | 40 | 40 | 40 |
| 74042 | CLR_1 | 0.6000 | 29.4 | 29.4 | 29.4 |
| 74043 | SS_GEN1 | 0.6000 | 42 | 42 | 42 |
| 74399 | BHPLPLAN | 13.800 | 100 | 100 | 100 |
| 76351 | RCDC W | 230.00 | -130 | -130 | -130 |
| 76404 | DRYFORK | 19.000 | 420 | 420 | 420 |
| 79015 | CRAIG 1 | 22.000 | 451 | 451 | 451 |
| 79016 | CRAIG 2 | 22.000 | 451 | 451 | 451 |
| 79017 | CRAIG 3 | 22.000 | 433.8 | 433.8 | 433.8 |
| 79019 | MORRO1-2 | 12.500 | 81 | 81 | 81 |
| 79019 | MORRO1-2 | 12.500 | 81 | 81 | 81 |
| 79040 | HAYDEN1 | 18.000 | 175 | 175 | 175 |
| 79041 | HAYDEN2 | 22.000 | 250 | 250 | 250 |
| 79123 | FONTNLE | 4.1600 | 9.5 | 9.5 | 9.5 |
| 79154 | FLGORG1 | 11.500 | 50 | 50 | 50 |
| 79155 | FLGORG2 | 11.500 | 50 | 50 | 50 |
| 79156 | FLGORG3 | 11.500 | 50 | 50 | 50 |
| 79157 | BMESA1-2 | 11.000 | 42 | 42 | 42 |
| 79157 | BMESA1-2 | 11.000 | 42 | 42 | 42 |
| 79158 | NUCLA 1 | 13.800 | 12.6 | 12.6 | 12.6 |
| 79159 | NUCLA 2 | 13.800 | 12.6 | 12.6 | 12.6 |
| 79160 | NUCLA 3 | 13.800 | 12.6 | 12.6 | 12.6 |
| 79161 | NUCLA 4 | 13.800 | 72 | 72 | 72 |
| 79162 | CRYSTAL | 12.500 | 27 | 27 | 27 |
| 79164 | TOWAOC | 6.9000 | 11 | 11 | 11 |
| 79166 | MOLINA-L | 4.2000 | 4.5 | 4.5 | 4.5 |
| 79172 | MOLINA-U | 4.2000 | 8.5 | 8.5 | 8.5 |
| 79176 | MCPHEE | 2.4000 | 1 | 1 | 1 |




Figure B2: One Line Diagram with Addition of GI-2012-3